

TYPE SLIM GRAPHITE

Test report

TEST REPORT FOR SPECIFIC THERMAL OUTPUT
OF FLOOR HEATING CONSTRUCTION IN ACC. TO EN 1264



IGE

Institut für
GebäudenEnergetik

Lehrstuhl für
Heiz- und
Raumluftechnik



Universität Stuttgart



The report shall not be reproduced except in full without the written approval of the testing lab. The test results release only to the items tested
The test laboratory is accredited in acc. to ISO/IEC 17025 by DAR.
Acceptances from certification bodies: DINCERTOCO / RAL / AFNOR / BSI / AENOR





SPECIFIC THERMAL OUTPUT TESTING IN ACC. TO EN 1264 PART. 2, FLOOR HEATING SYSTEM

1. TEST METHOD

Initial test of floor heating system

2. INSTITUT:

Institut für GebäudeEnergetik Lehrstuhl für Heiz- und Raumlufttechnik der Universität Stuttgart
Pfaffenwaldring 35 - D-70569 Stuttgart-Vaihingen

3. CLIENT:

COMISA S.p.A. - Via Neziole, 27 - 25055 - Pisogne (Bs) - ITALY

4. MANUFACTURER:

The Client

5. SYSTEM DESCRIPTION

trademark:	SISTEMA SLIM GRAFITE					
construction:	Type A					
spacing in m:	0,050	0,100	0,150	0,200	0,250	0,300

Pipe:

material:	PE-RT / Al / PE/RT (diffusiondicht)					
diameter:	0,016 m					
thickness:	0,022 m					
eff. heat conductivity:	0,387 W/mK					

Systeme layer plate: plate with nubs of polystyrol

volume of nubs in %:	7,69	7,43	7,34	7,30	7,28	7,26
heat conductivity of nubs:	0,4 W/m K					

Load distribution layer:

material:	Concrete floor
thickness:	0,045 m
heat conductivity:	1,20 W/m K

6. TEST RESULTS:

Limit specific thermal output in W/m ²	100,0	98,5	96,0	62,6	86,6	84,5
Limit temperature difference in K:	13,3	15,5	17,5	19,4	21,0	22,4

7. PROCEDURE OF TESTING:

The system was tested by calculation method.
 An additional experimentell testing is not necessary.

8. CALCULATION RESULTS:

Characteristic curves: $q = k_H \cdot \Delta\theta_H$

ADD. FLOOR COVERING	0,00	0,05	0,10	0,15	m ² K/W
Spacing T	Equivalent coefficient for heat transfer kH				
0,050 m	7,534	5,372	4,167	3,403	W/m ² K
0,100 m	6,342	4,670	3,708	3,082	W/m ² K
0,150 m	5,482	4,137	3,350	2,822	W/m ² K
0,200 m	4,756	3,673	3,028	2,583	W/m ² K
0,250 m	4,128	3,261	2,738	2,366	W/m ² K
0,300 m	3,592	2,900	2,479	2,170	W/m ² K



Prof. Dr.-Ing. M. Schmidt

Universität Stuttgart
Institut für GebäudeEnergetik
 Pfaffenwaldring 35 · 70569 Stuttgart
 Tel.: (+49)711 / 685 620 85
 Fax: (+49)711 / 685 620 96
www.ige.uni-stuttgart.de




Dr.-Ing. Chr. Beck

SPECIFIC THERMAL OUTPUT TESTING IN ACC. TO EN 1264 PART. 2, FLOOR HEATING SYSTEM

LIMIT CURVES Spacing T = 0,050 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	$m^2 K / W$
9	Limit temperature difference	13,3	18,6	24,0	29,4	K
K	Limit specific thermal output	100,0	100,0	100,0	100,0	W / m^2
15	Limit temperature difference	23,2	32,6	42,0	51,4	K
K	Limit temperature difference	175,0	175,0	175,0	175,0	

Spacing T = 0,050 m




CALCULATION FACTORS		Spacing T = 0,050 m			
Resistance of floor covering	0,000	0,050	0,100	0,150	$m^2 K / M$
Factor B	6,735	6,725	6,719	6,716	$W / m^2 K$
Factor a_b	1,058	0,764	0,598	0,491	
Spacing factor a_T	1,230	1,188	1,156	1,134	
Spacing exponent m_T		0,333			
Covering factor a_U	1,069	1,056	1,043	1,037	
Covering exponent m_U		0,000			
Pipe factor A_D	1,013	1,013	1,012	1,011	
Pipe exponent m_D		-1,000			
Limit curve coefficient B_G		100,000			
Limit curve exponent n_G		0,000			

LIMIT CURVES Spacing T = 0,100 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	$m^2 K / W$
9	Limit temperature difference	15,5	21,3	27,0	32,4	K
K	Limit specific thermal output	98,5	99,4	100,0	100,5	W / m^2
15	Limit temperature difference	27,2	37,3	47,2	56,8	K
K	Limit temperature difference	172,8	174,3	175,0	175,0	W / m^2

Spacing T = 0,100 m




CALCULATION FACTORS		Spacing T = 0,100 m			
Resistance of floor covering	0,000	0,050	0,100	0,150	$m^2 K / M$
Factor B	6,758	6,743	6,734	6,728	$W / m^2 K$
Factor a_b	1,035	0,752	0,591	0,486	
Spacing factor a_T	1,230	1,188	1,156	1,134	
Spacing exponent m_T		-0,333			
Covering factor a_U	1,063	1,050	1,039	1,034	
Covering exponent m_U		0,000			
Pipe factor A_D	1,013	1,013	1,012	1,011	
Pipe exponent m_D		-1,000			
Limit curve coefficient B_G		91,607			
Limit curve exponent n_G		0,027			

LIMIT CURVES Spacing T = 0,150 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	$m^2 K / W$
9	Limit temperature difference	17,5	23,7	29,7	35,4	K
K	Limit specific thermal output	96,0	98,1	99,6	100,9	W / m^2
15	Limit temperature difference	30,7	41,5	52,1	62,0	K
K	Limit temperature difference	168,4	172,0	174,7	175,0	W / m^2

Spacing T = 0,150 m




CALCULATION FACTORS	Spacing T = 0,150 m				
Resistance of floor covering	0,000	0,050	0,100	0,150	$m^2 K / M$
Factor B	6,776	6,757	6,746	6,739	$W / m^2 K$
Factor a_b	1,035	0,752	0,591	0,486	
Spacing factor a_T	1,230	1,188	1,156	1,134	
Spacing exponent m_T		-1,000			
Covering factor a_U	1,057	1,046	1,035	1,031	
Covering exponent m_U		0,000			
Pipe factor A_D	1,040	1,034	1,029	1,024	
Pipe exponent m_D		-1,000			
Limit curve coefficient B_G		78,641			
Limit curve exponent n_G		0,070			

LIMIT CURVES Spacing T = 0,200 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	$m^2 K / W$
9	Limit temperature difference	19,5	26,1	32,5	38,7	K
K	Limit specific thermal output	92,6	95,9	98,4	100,5	W / m^2
15	Limit temperature difference	34,2	45,8	57,0	67,7	K
K	Limit temperature difference	162,5	168,2	172,6	175,0	W / m^2

Spacing T = 0,200 m




CALCULATION FACTORS	Spacing T = 0,200 m				
Resistance of floor covering	0,000	0,050	0,100	0,150	$m^2 K / M$
Factor B	6,788	6,768	6,756	6,748	$W / m^2 K$
Factor a_b	1,035	0,752	0,591	0,486	
Spacing factor a_T	1,230	1,188	1,156	1,134	
Spacing exponent m_T		-1,667			
Covering factor a_0	1,051	1,041	1,032	1,028	
Covering exponent m_0		0,000			
Pipe factor A_D	1,046	1,040	1,035	1,030	
Pipe exponent m_D		-1,000			
Limit curve coefficient B_G		65,277			
Limit curve exponent n_G		0,118			

LIMIT CURVES Spacing T = **0,250 m**

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	$m^2 K / W$
9	Limit temperature difference	21,0	27,9	34,4	41,0	K
K	Limit specific thermal output	86,6	90,9	94,2	97,0	W / m^2
15	Limit temperature difference	36,8	48,9	60,3	70,0 *	K
K	Limit temperature difference	152,0	159,4	165,2	165,6 **	W / m^2

* Specific thermal output with the limits of max temperature difference | ** Max temperature difference for the pipe in K

Spacing T = **0,250 m**




CALCULATION FACTORS		Spacing T = 0,250 m			
Resistance of floor covering	0,000	0,050	0,100	0,150	$m^2 K / M$
Factor B	6,795	6,775	6,763	6,755	$W / m^2 K$
Factor a_b	1,035	0,752	0,591	0,486	
Spacing factor a_T	1,230	1,188	1,156	1,134	
Spacing exponent m_T		-2,333			
Covering factor a_U	1,045	1,035	1,028	1,024	
Covering exponent m_U		0,000			
Pipe factor A_D	1,051	1,046	1,041	1,035	
Pipe exponent m_D		-1,000			
Limit curve coefficient B_G		51,819			
Limit curve exponent n_G		0,169			

LIMIT CURVES Spacing T = 0,300 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	$m^2 K / W$
9	Limit temperature difference	22,4	29,7	36,5	43,5	K
K	Limit specific thermal output	80,5	86,2	90,6	94,5	W / m^2
15	Limit temperature difference	39,3	52,1	64,1	70,0 *	K
K	Limit temperature difference	141,3	151,2	158,8	151,9 **	W / m^2


* Specific thermal output with the limits of max temperature difference | ** Max temperature difference for the pipe in K

Spacing T = 0,300 m



CALCULATION FACTORS	Spacing T = 0,300 m				
Resistance of floor covering	0,000	0,050	0,100	0,150	$m^2 K / M$
Factor B	6,799	6,780	6,769	6,760	$W / m^2 K$
Factor a_B	1,035	0,752	0,591	0,486	
Spacing factor a_T	1,230	1,188	1,156	1,134	
Spacing exponent m_T		-3,000			
Covering factor a_U	1,040	1,031	1,024	1,021	
Covering exponent m_U		0,000			
Pipe factor A_D	1,053	1,049	1,044	1,039	
Pipe exponent m_D		-1,000			
Limit curve coefficient B_G		38,140			
Limit curve exponent n_G		0,240			

9. CONSTRUCTION DRAWING OF TEST SAMPLE:



10. CONFORMITY OF THE TECHNICAL DOCUMENTS

The system is type A of DIN 18560 part. 2.
The sketch on the technical documents are in acc. to EN 1264 part. 4.
The official technical documents should be sent to the Institut within 6 months.

TYPE SLIM GRAPHITE

Test report

TEST REPORT FOR SPECIFIC THERMAL OUTPUT
OF FLOOR HEATING CONSTRUCTION IN ACC. TO EN 1264



IGE

Institut für
GebäudenEnergetik

Lehrstuhl für
Heiz-und
Raumluftechnik



Universität Stuttgart



The report shall not be reproduced except in full without the written approval of the testing lab. The test results release only to the items tested
The test laboratory is accredited in acc. to ISO/IEC 17025 by DAR.
Acceptances from certification bodies: DINCERTOCO / RAL / AFNOR / BSI / AENOR



SPECIFIC THERMAL OUTPUT TESTING IN ACC. TO EN 1264 PART. 2, FLOOR HEATING SYSTEM

1. DECRPTION OF THE TEST METHOD:

The heating output of the looked floor system can be determined to EN 1264 part. 2. In part. 5 of EN 1264 instructions are given which changes are to be expected in the output (heating case and chilled case), if the arrangement of the space surfaces is changed. Thus the arrangement on the ground is, e.g., in the chilled case the case with the lowest output values, while in the heating case the arrangement on the ground proves the highest values.

2. TEST RESULTS:

2.1 PROCEDURE OF TESTING:

The standard specific thermal output the heating case is calculated to EN 1264 for 4 standard layers (R_1 to R_4):

$$R_{\lambda} = 0,0; 0,05; 0,1 \text{ and } 0,15 \text{ m}^2 \text{ K/W}$$

These theoretical values of the resistance cover the really seeming floor covering to a great extent, so that for the later use with these values or interpolations the system can be laid out.

2.2 RESULTS OF HEATING CASE IN ACC. TO EN 1264 PART. 2:

Characteristic curves:

$$q = k_H * \Delta\theta_H$$

ADD. FLOOR COVERING	0,00	0,05	0,10	0,15	m ² K/W
Spacing T	Equivalent coefficient for heat transfer k_H				
0,050 m	7,534	5,372	4,167	3,403	W/m ² K
0,100 m	6,342	4,670	3,708	3,082	W/m ² K
0,150 m	5,482	4,137	3,350	2,822	W/m ² K
0,200 m	4,756	3,673	3,028	2,583	W/m ² K
0,250 m	4,128	3,261	2,738	2,366	W/m ² K
0,300 m	3,592	2,900	2,479	2,170	W/m ² K

2.3 RESULTS OF CHILLED CASE IN ACC. TO EN 1264 PART. 5:

The results for the floor heating system in acc. to EN 1264 part. 2 has to be transmitted by calculation method in acc. to EN 1264 part. 5

ADD. FLOOR COVERING	α (W/m ² K)	$\Delta R_{\mu} = 1/\alpha - 1/10,8$ (m ² K/W)
Spacing T	Equivalent coefficient for heat transfer k_H	
Floor	10,8	0,0000
Floor	6,5	0,0613
Wall	8,0	0,0324
Wall	8,0	0,0324
Ceiling	6,5	0,0613
Ceiling	10,8	0,0000

3 CHARACTERISTIC CURVES FOR THE CASE OF CHILLED FLOOR

The cooling output of a floor system is reduced with the otherwise same conditions compared with the output of an under-floor heating system. A cause for this are the changed conditions on the heat transfer by convection on the surface of the floor. From part 5 on EN 1264 the respective heat transfer coefficients are known.

For the looked floor type THERMOCONCEPT STANDARD the following output values arise.

$$q = k_H \cdot \Delta\theta_H \quad \text{with} \quad \Delta\theta \text{ Temperature difference}$$

RA	0,05	0,10	0,15	0,20	0,25	0,30
K_{H1}	5,036	4,428	3,957	3,540	3,165	2,833
K_{H2}	3,964	3,553	3,226	2,929	2,658	2,417
K_{H3}	3,268	2,967	2,722	2,497	2,292	2,107
K_{H4}	2,780	2,547	2,355	2,177	2,014	1,868

Coefficient s of the characteristic curves for the different standard layers as a function of the pipe distance RA



Prof. Dr.-Ing. M. Schmidt

Universität Stuttgart
 Institut für GebäudeEnergetik
 Pfaffenwaldring 35 · 70569 Stuttgart
 Tel.: (+49)711 / 685 620 85
 Fax: (+49)711 / 685 620 96
 www.ige.uni-stuttgart.de



Dr.-Ing. Chr. Beck

The figures 1 to 6 show this connection again in graphic form.




Figure 1: cooling output in dependence of the temperature distance room - water for pipe distance RA 50 mm




Figure 2: cooling output in dependence of the temperature distance room - water for pipe distance RA 100 mm




Figure 3: cooling output in dependence of the temperature distance room - water for pipe distance RA 150 mm




Figure 4: cooling output in dependence of the temperature distance room - water for pipe distance RA 200 mm




Figure 5: cooling output in dependence of the temperature distance room - water for pipe distance RA 250 mm




Figure 6: cooling output in dependence of the temperature distance room - water for pipe distance RA 300 mm